

# Monthly Data Summary

## LIDDELL MONTHLY DATA SUMMARY JANUARY 2019

LICENCE NO	2122
LICENCE HOLDER	AGL MACQUARIE
REPORTING PERIOD	JANUARY 2019

### A1 Licence Holder

Licence Number 2122  
 Licence Holder AGL MACQUARIE  
 Trading Name (if applicable)  
 ABN 18 167 859 494

### A2 Premises to which Licence Applies (if applicable)

Common Name (if any) LIDDELL POWER STATION  
 Premises NEW ENGLAND HIGHWAY MUSWELLBROOK NSW 2333

### A3 Activities to which Licence Applies

Electricity Generating Works  
 Coal Works

### A4 Other Activities (if applicable)

Helicopter-related facilities  
 Chemical storage  
 Operation of Emergency 1.5 MW diesel generator  
 Operation of Gas turbine  
 Sewage treatment  
 Waste storage

### A5 Fee-Based Activity Classifications

**Note** that the fee based activity classification is used to calculate the administrative fee.

Fee-based activity	Activity scale	Unit of measure
Coal works	> 5,000,000.00	T handled
Generation of electrical power from coal	> 4,000.00	Gwh generated

# Monthly Data Summary

## Discharge & Monitoring Point 7

301204 East 6416350 North

Discharge to Air

In the flue gases of unit 1 boiler labelled as "Unit 1 Boiler 1-2 Chimney Stack" on plan no. LD 800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	450.9	602.9	760.1	1500 mg/m <sup>3</sup>
JANUARY 2019	15/02/2019		parts per million				219.7	293.7	370.3	700 ppm
JANUARY 2019	15/02/2019	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	714.1	953.2	1292.2	
JANUARY 2019	15/02/2019		parts per million				249.9	333.5	452.1	600 ppm
JANUARY 2019	15/02/2019	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	1.6	4.3	8.2	20%

Comments:

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 1 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-18	8/11/2018	Cadmium	milligrams per cubic metre	1	1	<0.0001	1.0
Oct-18	8/11/2018	Chlorine	milligrams per cubic metre	1	1	0.0	200
Oct-18	8/11/2018	Copper	milligrams per cubic metre	1	1	0.0017	
Oct-18	8/11/2018	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.058	5
Oct-18	8/11/2018	Hydrogen chloride	milligrams per cubic metre	1	1	26.0	100
Oct-18	8/11/2018	Mercury	milligrams per cubic metre	1	1	0.00330	1.0
Oct-18	8/11/2018	Nitrogen oxides	milligrams per cubic metre	1	1	810	1500
Oct-18	8/11/2018	Solid particles	milligrams per cubic metre	1	1	5.5	100
Oct-18	8/11/2018	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	2.000	100
Oct-18	8/11/2018	Sulphur dioxide	milligrams per cubic metre	1	1	1200	
Oct-18	8/11/2018	Total fluoride	milligrams per cubic metre	1	1	12.0	50
Oct-18	8/11/2018	Volatile organic compounds	milligrams per cubic metre	1	1	<0.03	

Comments:

Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 1.

# Monthly Data Summary

## Discharge & Monitoring Point 8

301204 East 6416350 North

In the flue gases of unit 2 boiler labelled as "Unit 2 Boiler 1-2 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	421	567	684	1500 mg/m <sup>3</sup>
JANUARY 2019	15/02/2019		parts per million				205	276	333	700 ppm
JANUARY 2019	15/02/2019	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	719	909	1214	
JANUARY 2019	15/02/2019		parts per million				252	318	425	600 ppm
JANUARY 2019	15/02/2019	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	4.9	7.2	10.7	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 2 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Mar-18	12/04/2018	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
Mar-18	12/04/2018	Chlorine	milligrams per cubic metre	1	1	<0.007	200
Mar-18	12/04/2018	Copper	milligrams per cubic metre	1	1	0.0040	
Mar-18	12/04/2018	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.019	5
Mar-18	12/04/2018	Hydrogen chloride	milligrams per cubic metre	1	1	8.7	100
Mar-18	12/04/2018	Mercury	milligrams per cubic metre	1	1	<0.00080	1.0
Mar-18	12/04/2018	Nitrogen oxides	milligrams per cubic metre	1	1	550	1500
Mar-18	12/04/2018	Solid particles	milligrams per cubic metre	1	1	37.0	100
Mar-18	12/04/2018	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	0.880	100
Mar-18	12/04/2018	Sulphur dioxide	milligrams per cubic metre	1	1	900	
Mar-18	12/04/2018	Total fluoride	milligrams per cubic metre	1	1	8.2	50
Mar-18	12/04/2018	Volatile organic compounds	milligrams per cubic metre	1	1	0.940	
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 2.							

# Monthly Data Summary

## Discharge & Monitoring Point 9

301204 East 6416350 North

In the flue gases of unit 3 boiler labelled as "Unit 3 Boiler 3-4 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	432.8	603.5	795.6	1500 mg/m <sup>3</sup>
JANUARY 2019	15/02/2019		parts per million				210.9	294.0	387.6	700 ppm
JANUARY 2019	15/02/2019	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	801.1	1073.9	1576.9	
JANUARY 2019	15/02/2019		parts per million				280.3	375.8	551.7	600 ppm
JANUARY 2019	15/02/2019	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	4.5	6.6	9.1	20%

Comments:

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 3 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-17	1/12/2017	Cadmium	milligrams per cubic metre	1	1	<0.0001	1.0
Oct-17	1/12/2017	Chlorine	milligrams per cubic metre	1	1	0.0	200
Oct-17	1/12/2017	Copper	milligrams per cubic metre	1	1	0.0037	
Oct-17	1/12/2017	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.02	5
Oct-17	1/12/2017	Hydrogen chloride	milligrams per cubic metre	1	1	20.0	100
Oct-17	1/12/2017	Mercury	milligrams per cubic metre	1	1	0.00051	1.0
Oct-17	1/12/2017	Nitrogen oxides	milligrams per cubic metre	1	1	770	1500
Oct-17	1/12/2017	Solid particles	milligrams per cubic metre	1	1	42.0	100
Oct-17	1/12/2017	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	1.700	100
Oct-17	1/12/2017	Sulphur dioxide	milligrams per cubic metre	1	1	1300	
Oct-17	1/12/2017	Total fluoride	milligrams per cubic metre	1	1	9.8	50
Oct-17	1/12/2017	Volatile organic compounds	milligrams per cubic metre	1	1	<0.02	

Comments:

Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 3.

# Monthly Data Summary

## Discharge & Monitoring Point 10

301204 East 6416350 North

In the flue gases of unit 4 boiler labelled as "Unit 4 Boiler 3-4 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	363.9	528.2	660.5	1500 mg/m <sup>3</sup>
JANUARY 2019	15/02/2019		parts per million				177.3	257.3	321.8	700 ppm
JANUARY 2019	15/02/2019	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	704.5	944.6	1425.6	
JANUARY 2019	15/02/2019		parts per million				246.5	330.5	498.8	600 ppm
JANUARY 2019	15/02/2019	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	3.6	6.1	15.2	20%
<b>Comments:</b>										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 4 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>			
Oct-18	29/11/2018	Cadmium	milligrams per cubic metre	1	1	<0.0001	1.0			
Oct-18	29/11/2018	Chlorine	milligrams per cubic metre	1	1	0.0	200			
Oct-18	29/11/2018	Copper	milligrams per cubic metre	1	1	0.0007				
Oct-18	29/11/2018	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.013	5			
Oct-18	29/11/2018	Hydrogen chloride	milligrams per cubic metre	1	1	21.0	100			
Oct-18	29/11/2018	Mercury	milligrams per cubic metre	1	1	0.00037	1.0			
Oct-18	29/11/2018	Nitrogen oxides	milligrams per cubic metre	1	1	540	1500			
Oct-18	29/11/2018	Solid particles	milligrams per cubic metre	1	1	16.0	100			
Oct-18	29/11/2018	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	0.900	100			
Oct-18	29/11/2018	Sulphur dioxide	milligrams per cubic metre	1	1	1100				
Oct-18	29/11/2018	Total fluoride	milligrams per cubic metre	1	1	11.0	50			
Oct-18	29/11/2018	Volatile organic compounds	milligrams per cubic metre	1	1	<0.2				
<b>Comments:</b> Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 4.										

# Monthly Data Summary

## Discharge & Monitoring Point 12

Discharge to waters <301204 East 6416350 North> Update

Liddell Outfall Canal

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Ammonia	milligrams per litre	Fortnightly	3	0.03	0.05	0.06	-
JANUARY 2019	15/02/2019	Antimony	milligrams per litre	Fortnightly	3	0.008	0.008	0.009	
JANUARY 2019	15/02/2019	Arsenic	milligrams per litre	Fortnightly	3	0.007	0.008	0.008	-
JANUARY 2019	15/02/2019	Barium	milligrams per litre	Fortnightly	3	0.104	0.106	0.107	
JANUARY 2019	15/02/2019	Beryllium	milligrams per litre	Fortnightly	3	<0.001	<0.001	<0.001	-
JANUARY 2019	15/02/2019	Boron	milligrams per litre	Fortnightly	3	1.21	1.25	1.28	
JANUARY 2019	15/02/2019	Cadmium	milligrams per litre	Fortnightly	3	<0.0001	<0.0001	<0.0001	-
JANUARY 2019	15/02/2019	Chlorine	milligrams per litre	Fortnightly	3	0.1	0.16	0.23	
JANUARY 2019	15/02/2019	Chromium	milligrams per litre	Fortnightly	3	<0.01	<0.01	<0.01	-
JANUARY 2019	15/02/2019	Chromium (total)	milligrams per litre	Fortnightly	3	<0.001	<0.001	<0.001	
JANUARY 2019	15/02/2019	Cobalt	milligrams per litre	Fortnightly	3	<0.001	0.0005	<0.001	-
JANUARY 2019	15/02/2019	Conductivity	uS/cm	Fortnightly	3	2820.0	2850.0	2880.0	
JANUARY 2019	15/02/2019	Copper	milligrams per litre	Fortnightly	3	0.004	0.005	0.005	-
JANUARY 2019	15/02/2019	Flouride	milligrams per litre	Fortnightly	3	<0.500	0.95	1.35	
JANUARY 2019	15/02/2019	Lead	milligrams per litre	Fortnightly	3	<0.001	<0.001	<0.001	-
JANUARY 2019	15/02/2019	Manganese	milligrams per litre	Fortnightly	3	0.009	0.009	0.01	
JANUARY 2019	15/02/2019	Mercury	milligrams per litre	Fortnightly	3	<0.0001	<0.0001	<0.0001	-
JANUARY 2019	15/02/2019	Methylene Blue Active Substance	milligrams per litre	Fortnightly	3	<0.1	0.05	<0.1	
JANUARY 2019	15/02/2019	Molybdenum	milligrams per litre	Fortnightly	3	0.12	0.122	0.125	-
JANUARY 2019	15/02/2019	Nickel	milligrams per litre	Fortnightly	3	0.005	0.005	0.006	
JANUARY 2019	15/02/2019	Nitrogen (total)	milligrams per litre	Fortnightly	3	0.3	0.47	0.7	-
JANUARY 2019	15/02/2019	Oil and Grease	milligrams per litre	Weekly	5	<5	<5	<5	
JANUARY 2019	15/02/2019	pH	pH Units	Daily	31	8.1	8.4	8.5	-
JANUARY 2019	15/02/2019	Phosphorus	milligrams per litre	Fortnightly	3	0.01	0.02	0.04	

# Monthly Data Summary

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Selenium	milligrams per litre	Fortnightly	3	<0.01	<0.01	<0.01	-
JANUARY 2019	15/02/2019	Sulfur	milligrams per litre	Fortnightly	3	733	770	790	
JANUARY 2019	15/02/2019	Temperature	milligrams per litre	Fortnightly	3	34	34.2	34.5	
JANUARY 2019	15/02/2019	Tin	milligrams per litre	Fortnightly	3	<0.001	<0.001	<0.001	-
JANUARY 2019	15/02/2019	Total Dissolved Solids	milligrams per litre	Fortnightly	3	1970	2063	2130	
JANUARY 2019	15/02/2019	Total Organic Carbon	milligrams per litre	Fortnightly	3	6	6.7	8	-
JANUARY 2019	15/02/2019	TSS	milligrams per litre	Fortnightly	3	<1	0.67	1	
JANUARY 2019	15/02/2019	Vanadium	milligrams per litre	Fortnightly	3	0.01	0.01	0.02	-
JANUARY 2019	15/02/2019	Zinc	milligrams per litre	Fortnightly	3	<0.005	<0.005	<0.005	
Comments									

# Monthly Data Summary

Comments									
Discharge & Monitoring Point 13									
Discharge to waters <301204 East 6416350 North> Update									
Liddell Oil and Grit Trap									
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Ammonia	milligrams per litre	Fortnightly	3	0.11	0.12	0.2	-
JANUARY 2019	15/02/2019	Antimony	milligrams per litre	Fortnightly	3	0.007	0.008	0.009	
JANUARY 2019	15/02/2019	Arsenic	milligrams per litre	Fortnightly	3	0.007	0.007	0.008	-
JANUARY 2019	15/02/2019	Barium	milligrams per litre	Fortnightly	3	0.1	0.103	0.104	
JANUARY 2019	15/02/2019	Beryllium	milligrams per litre	Fortnightly	3	<0.001	<0.001	<0.001	-
JANUARY 2019	15/02/2019	Boron	milligrams per litre	Fortnightly	3	1.16	1.2	1.26	
JANUARY 2019	15/02/2019	Cadmium	milligrams per litre	Fortnightly	3	<0.0001	<0.0001	<0.0001	-
JANUARY 2019	15/02/2019	Chlorine	milligrams per litre	Fortnightly	3	0.06	0.09	0.11	
JANUARY 2019	15/02/2019	Chromium	milligrams per litre	Fortnightly	3	<0.01	<0.01	<0.01	-
JANUARY 2019	15/02/2019	Chromium (total)	milligrams per litre	Fortnightly	3	<0.001	<0.001	<0.001	
JANUARY 2019	15/02/2019	Cobalt	milligrams per litre	Fortnightly	3	<0.001	<0.001	<0.001	-
JANUARY 2019	15/02/2019	Conductivity	uS/cm	Fortnightly	3	2660.0	2713.3	2740.0	
JANUARY 2019	15/02/2019	Copper	milligrams per litre	Fortnightly	3	0.004	0.005	0.006	-
JANUARY 2019	15/02/2019	Flouride	milligrams per litre	Fortnightly	3	<0.100	0.803	1.29	
JANUARY 2019	15/02/2019	Lead	milligrams per litre	Fortnightly	3	<0.001	0.001	0.002	-
JANUARY 2019	15/02/2019	Manganese	milligrams per litre	Fortnightly	3	0.01	0.011	0.013	
JANUARY 2019	15/02/2019	Mercury	milligrams per litre	Fortnightly	3	<0.0001	<0.0001	<0.0001	-
JANUARY 2019	15/02/2019	Methylene Blue Active Substance	milligrams per litre	Fortnightly	3	<0.1	<0.1	<0.1	
JANUARY 2019	15/02/2019	Molybdenum	milligrams per litre	Fortnightly	3	0.113	0.117	0.121	-
JANUARY 2019	15/02/2019	Nickel	milligrams per litre	Fortnightly	3	0.004	0.006	0.007	
JANUARY 2019	15/02/2019	Nitrogen (total)	milligrams per litre	Fortnightly	3	0.4	0.4	0.4	-
JANUARY 2019	15/02/2019	Oil and Grease	milligrams per litre	Weekly	5	<5	<5	<5	
JANUARY 2019	15/02/2019	pH	pH Units	Daily	31	7.5	8.25	8.6	-



# Monthly Data Summary

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Phosphorus	milligrams per litre	Fortnightly	3	<0.01	0.02	0.04	
JANUARY 2019	15/02/2019	Selenium	milligrams per litre	Fortnightly	3	<0.01	<0.01	<0.01	-
JANUARY 2019	15/02/2019	Sulfur	milligrams per litre	Fortnightly	3	662	699	738	
JANUARY 2019	15/02/2019	Temperature	milligrams per litre	Fortnightly	3	29.9	30.3	30.7	
JANUARY 2019	15/02/2019	Tin	milligrams per litre	Fortnightly	3	<0.001	<0.001	<0.001	-
JANUARY 2019	15/02/2019	Total Dissolved Solids	milligrams per litre	Fortnightly	3	1830	1907	2050	
JANUARY 2019	15/02/2019	Total Organic Carbon	milligrams per litre	Fortnightly	3	6	6.7	8	-
JANUARY 2019	15/02/2019	TSS	milligrams per litre	Fortnightly	3	1	2	3	
JANUARY 2019	15/02/2019	Vanadium	milligrams per litre	Fortnightly	3	0.01	0.01	0.01	-
JANUARY 2019	15/02/2019	Zinc	milligrams per litre	Fortnightly	3	<0.005	<0.005	<0.005	
Comments									

## Discharge & Monitoring Point 14

Discharge to waters <301204 East 6416350 North> Update

The skimmer dam overflow spillway, located at the left abutment of the skimmer dam.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Arsenic	milligrams per litre	Weekly	5	0.036	0.0436	0.052	-
JANUARY 2019	15/02/2019	Boron	milligrams per litre	Weekly	5	1.78	1.886	1.97	
JANUARY 2019	15/02/2019	Cadmium	milligrams per litre	Weekly	5	<0.0001	0.00008	0.0002	-
JANUARY 2019	15/02/2019	Chromium	milligrams per litre	Weekly	5	<0.01	<0.01	<0.01	-
JANUARY 2019	15/02/2019	Chromium (total)	milligrams per litre	Weekly	5	<0.001	0.0009	0.002	
JANUARY 2019	15/02/2019	Conductivity	uS/cm	Weekly	5	2910.0	2950.0	3110.0	
JANUARY 2019	15/02/2019	Copper	milligrams per litre	Weekly	5	<0.001	<0.001	<0.001	-
JANUARY 2019	15/02/2019	Flouride	milligrams per litre	Weekly	5	2.3	2.38	2.5	
JANUARY 2019	15/02/2019	Lead	milligrams per litre	Weekly	5	<0.001	<0.001	<0.001	-
JANUARY 2019	15/02/2019	Mercury	milligrams per litre	Weekly	5	<0.0001	<0.0001	<0.0001	-
JANUARY 2019	15/02/2019	Oil and Grease	milligrams per litre	Weekly	5	<5	<5	<5	

# Monthly Data Summary

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	pH	pH Units	Weekly	5	8.0	8.1	8.2	-
JANUARY 2019	15/02/2019	Selenium	milligrams per litre	Weekly	5	0.02	0.022	0.03	-
JANUARY 2019	15/02/2019	TSS	milligrams per litre	Weekly	5	1	4.2	7	
JANUARY 2019	15/02/2019	Zinc	milligrams per litre	Weekly	5	<0.005	<0.005	<0.005	
Comments									

# Monthly Data Summary

## Details of Non-Compliance with Licence

Licence condition number not complied with

N/A

Summary of particulars of the non-compliance **(NO MORE THAN 50 WORDS)**

If required, further details on particulars of non-compliance

-

Date(s) when the non-compliance occurred, if applicable

If applicable, registration numbers of any vehicles or the chassis number of any mobile plant involved in the non-compliance

Cause of non-compliance

Action taken or that will be taken to mitigate any adverse effects of the non-compliance

Action taken or that will be taken to prevent a recurrence of the non-compliance