LIDDELL MONTHLY DATA SUMMARY NOVEMBER 2014

LICENCE NO	2122			
LICENCE HOLDER AGL MACQUARIE				
REPORTING PERIOD	01 / 11/ 2014 to 30 / 11/ 2014			

A1 Licence Holder

Licence Number 2122

Licence Holder AGL MACQUARIE

Trading Name (if applicable)

ABN 18 167 859 494

A2 Premises to which Licence Applies (if applicable)

Common Name (if any) LIDDELL POWER STATION

Premises NEW ENGLAND HIGHWAY MUSWELLBROOK NSW 2333

A3 Activities to which Licence Applies

Electricity Generating Works

Coal Works

A4 Other Activities (if applicable)

Helicopter-related facilities

Chemical storage

Operation of Emergency 1.5 MW diesel generator

Operation of Gas turbine

Sewage treatment

Waste storage

A5 Fee-Based Activity Classifications

Note that the fee based activity classification is used to calculate the administrative fee.							
Fee-based activity	Activity scale	Unit of measure					
Coal works	> 5,000,000.00	T handled					
Generation of electrical power from coal	> 4,000.00	Gwh generated					

Licence 2122 Page 1

Discharge & Monitoring Point 7

301204 East 6416350 North Discharge to Air

In the flue gases of unit 1boiler labelled as "Unit 1 Boiler 1-2 Chimney Stack" on plan no. LD 800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	No. of samples you collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit	Notes
Nov-14	12/12/2014	Nitrogen Oxides meter	milligrams per cubic meter	Continuous	>99%	455	647	807	1500	Note
Nov-14	12/12/2014		parts per million	Continuous	29976	221	315	393	700	Note
Nov-14	12/12/2014		milligrams per cubic metre	Continuous	>99%	862	1047	1335	1600	Note
Nov-14	12/12/2014	Sulphur dioxide	parts per million	Continuous	>33/6	302	366	467	600	Note
Nov-14	12/12/2014	Opacity	percent %	Continuous	>99%	3.6	8.3	16.9	20.0%	Note

Comments:

Note - Results from continuous emission monitor located on chimney stack, as part of EPL 2122

Discharge & Monitoring Point 8

301204 East 6416350 North

In the flue gases of unit 2 boiler labelled as "Unit 2 Boiler 1-2 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	No. of samples you collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit	Notes
Nov-14	12/12/2014	Nitrogen Oxides	milligrams per cubic meter	Continuous	>99%	290	509	667	1500	Note
Nov-14	12/12/2014		parts per million	Continuous	29976	141	248	325	700	Note
Nov-14	12/12/2014		milligrams per cubic metre	Continuous	>99%	738	1047	1229	1600	Note
Nov-14	12/12/2014	Sulpriul dioxide	Sulphur dioxide parts per million	Continuous	25376	258	366	430	600	Note
Nov-14	12/12/2014	Opacity	percent %	Continuous	>99%	0.2	1.6	3.9	20.0%	Note

Comments:

Note - Results from continuous emission monitor located on chimney stack, as part of EPL 2122

Licence 2122 Page 2

Discharge & Monitoring Point 9

301204 East 6416350 North

In the flue gases of unit 3 boiler labelled as "Unit 3 Boiler 3-4 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	No. of samples you collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit	Notes
Nov-14	12/12/2014	Nitrogen Oxides	milligrams per cubic meter	Continuous	>99% –	37	489	776	1500	Note
Nov-14	12/12/2014		parts per million	Continuous		18	238	378	700	Note
Nov-14	12/12/2014	- Sulphur dioxide	milligrams per cubic metre	Continuous	>99%	5	931	1348	1600	Note
Nov-14	12/12/2014		parts per million	Continuous	29376	2	326	472	600	Note
Nov-14	12/12/2014	Opacity	percent %	Continuous	>99%	2.5	5.0	9.2	20.0%	Note
Comments:	•				•					

Note - Results from continuous emission monitor located on chimney stack, as part of EPL 2122

Discharge & Monitoring Point 10

301204 East 6416350 North

In the flue gases of unit 4 boiler labelled as "Unit 4 Boiler 3-4 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	No. of samples you collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit	Notes
Nov-14	12/12/2014	Nitrogen Oxides	milligrams per cubic meter	Continuous	>99%	314	575	773	1500	Note 1
Nov-14	12/12/2014		parts per million			153	280	377	700	Note1
Nov-14	12/12/2014	Sulphur dioxide milligrams per cubic metre parts per million		Continuous	>99%	1020	1160	1357	1600	Note 1
Nov-14	12/12/2014		Continuous	>9976	357	406	475	600	Note 1	
Nov-14	12/12/2014	Solid Particles	percent Opacity	Continuous	>99%	4.1	6.1	10.3	20.0%	Note 1

Comments:

Note - Results from continuous emission monitor located on chimney stack, as part of EPL 2122

Licence 2122 Page 3

Details of Non-Compliance with Licence

C2

Nil
Summary of particulars of the non-compliance (NO MORE THAN 50 WORDS)
NA NA
If required, further details on particulars of non-compliance
NA NA
Date(s) when the non-compliance occurred, if applicable
NA
If applicable, registration numbers of any vehicles or the chassis number of any mobile plant involved in the non-compliance
NA
Cause of non-compliance
NA NA
Action taken or that will be taken to mitigate any adverse effects of the non-compliance
NA
Action taken or that will be taken to prevent a recurrence of the non-compliance
NA

Licence 2122